



GOVERNMENT OF TAMIL NADU

DIRECTORATE OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

பொது சுகாதாரம் மற்றும் நோய்த் தடுப்பு மருந்துத்துறை

SELF DECLARED SANITATION CERTIFICATE

(Issued under G.O.(Ms)No. 276 of Health and Family Welfare (AB2) Department dated

23.09.2024 on the basis of affidavit by the applicant)

Certificate Number : TN00126TNI38374

Issued Date : 15-06-2026

Organization Type : Educational Institutions

Expiry Date : 14-06-2027


Name of the Organization : VELAMMAL VIDYALAYA SR SEC SCHOOL

Address : Penny Quic Garden, Muthuthevanpatty, Theni.


I, RAMESH SP owner/manager of the VELAMMAL VIDYALAYA SR SEC SCHOOL functioning as Educational Institutions located at Veerapandi in Theni district hereby declare that

- This Self-Declared Sanitation certificate is valid from 15-06-2026 to 14-06-2027 and will be renewed every year prior to the expiry of the current certificate with updated information.
- Our premises can accommodate 4300 people/pupils and has 175 urinals and 152 toilets which is proportionate to the number of users as per government norms.
- 50 Sanitation workers are deployed to clean the entire premises including Toilets, Common Area Spaces, etc., at regular intervals and proper record is maintained.
- The waste generated on our premises is properly processed and disposed of as per Solid Waste management Rules, 2016.
- There is no potential mosquito breeding area on the premises.
- The premises have adequate drinking water fountains on each floor of the premises.
- The self-declared certificate is displayed prominently on the premises along with the protocol

The Government reserves the right to inspect at any point of time and cause for rectification or cancel or suspend the certificate and take legal action if any conditions are violated.


MANAGER
VELAMMAL VIDYALAYA
PENNYQUIC GARDEN, MUTHUTHEVANPATTI
THENI - 625 531. (THENI DISTRICT)


PRINCIPAL
VELAMMAL VIDYALAYA
PENNY CUIC GARDEN
MUTHUTHEVANPATTI
THENI - 625 531.



Signature of the Owner/Manager



(அ) TN00126TNI38374 என்ற தனிப்பட்ட சான்றிதழ் எண்ணை
<https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/> ல் உள்ளிடு செய்து சரிபார்க்கவும்.

(அல்லது)

(ஆ) கைப்பேசியில் பार्சுகொடு படிப்பான் மூலம் இணையதளத்தில் சரிபார்க்கவும்.

Genuineness of the certificate can be verified by.

(a) Keying in the unique certificate number TN00126TNI38374 in the URL

<https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/>

(or)

(b) Reading the 2D barcode with mobile barcode reader and verify through online.



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

Andipatti-Sedapatti CWSS Treatment Plant, Vaigaidam,

Theni-625562. E-mail: wtltheni11@gmail.com

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2026/3015	Report Issue Date :	12.08.2026	Page No:01 of 02
Invoice Details:	128/Dt.08.08.2026/Amt.Rs.1652/-			

Client Name & Address Contact No / Email.ID	:	Velammal Vidyalaya (CBSE) School , Muthuthevanpatti, Theni -625534.			
Sample Name	:	Water – Drinking Water			
Sample /Lab No	:	3015-2			
Sample Source	:	Drinking Water			
Sample Description	:	Clear Colourless liquid			
Sample Submitted by	:	Customer			
Location & Date	:	In School & 08.08.2026			
Sample Container	:	Plastic – Good Condition			
Quantity of sample Received	:	2 Litres	Sample Condition on Receipt	:	Good
Sample Received On	:	08.08.2026	Environmental Condition	:	23 – 27 °C
Test Commenced on	:	10.08.2026	Test Completed on	:	11.08.2026

S.No	Parameters	Test Method		Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	Appearance	Visual observation	--	Clear	Clear	Clear
2	Odour	IS 3025: Part 5: 2018	--	Agreeable	Agreeable	Agreeable
3	Turbidity	IS 3025: Part 10: 2023	NTU	1	1	5
4	Total Dissolved Solids	IS 3025: Part 16: 2023	mg/L	95.9	500	2000
5	Conductivity	IS 3025: Part 14: 2013	µS/cm	137	-	-
6	P - Alkalinity	IS 3025: Part 23: 2023	mg/L	NIL	-	-
7	Calcium as Ca	IS 3025: Part 40: 1991	mg/L	3.75	75	200
8	Magnesium as Mg	IS 3025: Part 46: 2023	mg/L	1.5	30	100
9	Iron as Fe	IS 3025 (Part 53) : 2024	mg/L	0	0.3	1
10	Manganese as Mn	IS 3025 (Part 59) : 2023	mg/L	0	0.1	0.3
11	Ammonia as NH ₃	IS 3025 (Part 34) : 2023	mg/L	0.4	0.5	0.5

PRINCIPAL
VELAMMAL VIDYALAYA
PENNY CUIC GARDEN
MUTHUTHEVANPATTI
THENI - 625 531.

P. Selvi
Reviewed and Authorised by
P. Selvi – Asst. Executive Engineer

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD
DISTRICT WATER TESTING LABORATORY
Andipatti - Sedappatti, CWSS Treatment Plant, Vaigaidam,
Theni - 625562. E-mail: wtltheni11@gmail.com

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2026/3015-1	Report Issue Date:	12.08.2026	Page No : 01 of 01
Invoice Details:	128/D1 :08.08.2026	ULR. No	-----	

Client Name & Address Contact No / Email.ID	:	Velammal Vidyalaya (CBSE) School , Muthuthevanpatti, Theni -625534.			
Sample Name	:	Water - Drinking Water			
Sample / Lab No	:	3015-1			
Sample Source	:	Drinking Water			
Sample Description	:	Clear Colourless liquid			
Sample Submitted by	:	Customer			
Location & Date	:	In School & 08.08.2026			
Sample Container	:	Plastic - Good Condition			
Quantity of sample Received	:	2 Litres	Sample Condition on Receipt	:	Good
Sample Received on	:	08.08.2026	Environmental Condition	:	23 - 27 °C
Test Commenced on	:	10.08.2026	Test Completed on	:	11.08.2026

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500: 2012(RA:2023)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	pH @ 25°C	IS 3025: Part 11: 2022	--	6.7	6.5-8.5	6.5-8.5
2	Total Hardness as CaCO ₃	IS 3025: Part 21: 2009	mg/L	15	200	600
3	Total Alkalinity as CaCO ₃	IS 3025: Part 23: 2023	mg/L	25	200	600
4	Chloride as Cl	IS 3025: Part 32: 1988	mg/L	21	250	1000
5	Sulphate as SO ₄	IS 3025: (Part 24/Sec 1): 2022	mg/L	15	200	400
6	Nitrate as NO ₃	IS 3025: (Part 34/Sec-1): 2023	mg/L	5.8	45	45
7	Fluoride as F	IS 3025: (Part 60/Sec-1): 2023	mg/L	0.2	1.0	1.5

Remark: The tested sample conformed, As per IS: 10500:2012 (RA: 2023) Drinking water Acceptable Limit / Permissible Limit specification with respect to above tested parameters.

PRINCIPAL
VELAMMAL VIDYALAYA
PENNY CUIC GARDEN
End of the Report -----

P. Selvi 12/8/26
Reviewed and Authorised by
P. Selvi - Asst. Executive Engineer

Note: MUTHUTHEVANPATTI

1. The test results remain valid to 625562.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. The test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.

Issue No/ Date	01/01.09.2024	Amend .No / Date	00/-	Page No	01 of 01
----------------	---------------	------------------	------	---------	----------

Annexure C


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Date: 01/09/2026

It is certified that an inspection team headed by **BLOCK HEALTH SUPERVISOR**, from **PUBLIC HEALTH DEPARTMENT, MUTHUTHEVANPATTI, THENI** inspected the **VELAMMAL VIDYALAYA, Pennycuic Gardens, Theni - Kumili Highways, Muthuthevanpatti, Theni-625531, Tamilnadu** on 28/08/21 and on the basis of Water Test Report bearings / 2026 / 3015-1 dated 12.08.2026 of Tamilnadu Water Supply and Drainage Board, District Water Testing Laboratory, Theni - 625562, certified that the **VELAMMAL VIDYALAYA** has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central / State / U.T. Govt.

The Certificate is valid for a period of **ONE YEAR** from the date of issue.

Signature with Seal :


BLOCK HEALTH SUPERVISOR
GOVT PRIMARY HEALTH CENTRE

Name :

VEERAPANDI 625 534

Designation :

THENI DISTRICT

Name & Address of the Office / Department:

To,

THE CORRESPONDENT,

VELAMMAL VIDYALAYA,

Pennycuic Gardens,

Theni - Kumili Highways,

Muthuthevanpatti,

Theni-625531.


PRINCIPAL
VELAMMAL VIDYALAYA
PENNY CUIC GARDEN
MUTHUTHEVANPATTI
THENI - 625 531.